

Request for Proposal Ludlow Fire Department

The Ludlow Fire Department is accepting proposals for the purchase of fire hose.

All proposals should be submitted in a sealed envelope marked "Fire Hose Replacement Project" and addressed to:

City of Ludlow
51 Elm Street
P.O. Box 16188
Ludlow, KY 41015
Attention: Fire Chief Rob Dreyer

Proposals must be received no later than 4:00 p.m. Wednesday April 26, 2017

Proposals will be opened at 4:00 p.m. on Wednesday April 26, 2017. The City of Ludlow reserves the right to reject any or all proposals and take such actions as may be deemed necessary in the best interest of the City of Ludlow.

Contact Person: Should any questions arise, please contact Chief Rob Dreyer at 859-581-8600 or rdreyer@ludlow.org.

All requested hose must meet or exceed the requirements of NFPA 1961.

Description:

1.75" Firefighting attack hose, 50 foot in length, 100% polyester double jacketed rubber lined.

Hose shall be coupled with National Standard Thread couplings. Hose should be able to be reloaded when wet and be able to resist mold and mildew.

2.5" Firefighting attack hose, 50 foot in length, 100% polyester double jacketed rubber lined.

Hose shall be coupled with Old Cincinnati (3.095x 6) couplings. Hose should be able to be reloaded when wet and be able to resist mold and mildew.

3" Supply Hose, 50 foot in length, 100% polyester double jacketed rubber lined. Hose shall be

coupled with Old Cincinnati (3.095x6) couplings. Hose should be able to be reloaded when wet and be able to resist mold and mildew.

5" Supply Hose, 100 foot in length, 100% polyester double jacketed rubber lined. Hose shall be

coupled with unisex locking couplings. Hose should be able to be reloaded when wet and be able to resist mold and mildew.

**Request for Proposal
Ludlow Fire Department**

QUANTITY:

- 20 Each 1.75" attack fire hose – 50 foot sections
- 20 Each 2.5" attack fire hose – 50 foot sections
- 6 Each 3" supply hose – 50 foot sections
- 22 Each 5" supply hose – 100 foot sections

Bid Sheet:

Item	Meets RFP (Yes or No)	Bid Amount	Exceptions/Notes
Attack Hose 1.75"			
Attack Hose 2.5"			
Supply Hose 3"			
Supply Hose 5"			
Bid Total			

Any "No" response to Meets RFP question above requires comments below:

**Request for Proposal
Ludlow Fire Department**
